

2025 CATALOGUE

Cable Trunking
Cable Tray
Cable Ladder
Cable Basket
Hole Cable Tray

電綫槽 電纜托盤 電纜梯架 電綫籃 網篩橋架



Contents 目録

Pompany Milestones	公司裏程碑	2
Project Selection	工程項目例子	3-4
Product Code Guide	產品代號指南	5
Cable Trunking	電綫槽	6-11
Cable Tray	電纜托盤	12-16
Cable Ladder	電纜梯架	17-18
Cable Basket	電綫籃	19-33
Hole Cable Tray	網篩橋架	34-39
ISO 90001/14001/45001	ISO 國際標准化	40-42
UL Certification	美國UL認證	43-47
CE Certification	歐盟CE認證	48-50
	on of Compliance 祭電工符合性驗證	51-55
RoHS 2.0 Verificatio	on of Compliance S 環保符合性證書	56-60
UV Test Report(We UV 耐值	athering Resistance) 吴性老化檢測報告	61-69
•	ision Test Report 撞+衝擊檢測報告	70-75
Salt Spray Test Co	mpliance Report 鹽霧測試合規報告	76-79









Projects over 200 meters in height 高度超過**200**米項目


















Projects >500,000 m² GFA 建築面積超過50萬㎡項目









Cable trunking, tray, ladder, basket product codes 綫槽,托盤,梯架,綫籃 產品代號

MODEL SPECIFICATION 型號説明

PRODUCT TYPE 產品類	DIMENSION / THICKNESS 尺寸 / 厚度	FITTINGS 配件編號	OTHER 其他
綫槽 TRUNKING	Width × Height × Thickness 寬 × 高 × 厚度 Example: 200 * 100 * 1.2	C C: Cable trunking C代表電綫槽系列	R Hot-dip Galvanizing 熱浸鋅
托盤 TRAY	Width × Height × Thickness 寬 × 高 × 厚度 Example: 200 * 100 * 1.2	P P:Perforated Cable Tray P代表托盤系列	P Powder coated 噴塑 D Electro-galvanized 電鍍鋅
梯架 LADDER	Width × Height × Thickness 寬 × 高 × 厚度 Example: 200 * 100 * 1.2	T T:Ladder cable tray T代表梯式橋架系列	S Stainless Steel 不銹鋼
綫籃 BASKET	Width × Height × Thickness 寬 × 高 × 厚度 Example: 200 * 100 * 1.2	W W:Wire Mesh Cable Tray (Basket Tray) W代表網格橋架系列 (電綫籃)	

GY Brand Name(GuangYu) 品牌 (廣羽)

QJ Product Name(QiaoJia) 產品名稱 (電纜橋架)

STANDARDS

BS 4678 Part 1 Class 2 & 3 Corrosion Protection, BS1449, BSEN 50085-1,2-1, IEC 61084-1, 2-1, BSEN 10139, EN 10143, BSEN 10149

規格標准

BS 4678 Part 1 Class 2 & 3 抗蝕保護, BS1449, BSEN 50085-1,2-1, IEC 61084-1, 2-1, BSEN 10139, EN 10143, BSEN 10149

TRUNKING COVER TYPE

Snap-Lock (QT) Screw Fix (ST)

槽蓋款式

卡扣式彈性咬合自鎖蓋(自鎖蓋: QT) 螺絲旋緊固定直角蓋(螺絲蓋: ST)

MATERIAL

Galvanised Steel Sheet Mild Steel Stainless Steel Sheet SS304 (S), SS316 (X)

原料

鍍鋅鋼板 鋼板 不銹鋼板SS304(S),SS316(X)

LENGTH

Standard length of 2.44m, Other lengths available on request

長度

標准2m/3m 其他長度可按照客需要

THICKNESS

Comply to BS 4678 Other thicknesses can be made (0.9mm -2.0mm)

厚度

符合BS 4678要求 其他厚度由0.9mm-2.0mm 可按要求生產

FINISHES

Hot Dip Galvanized to BS729, ISO1460, 1461(H) Coloured Epoxy Powder Coating / High Grade Outdoor Powder (P)

表面處理

熱浸鋅符合標准BS729,ISO1460,1461 (H) 顏色聚脂油粉/高級戶外粉(P)

SEPARATE COMPARTMENTS

2 compartment (D), or multi compartment (T) as requested

槽内間格


可按照客人的要求制成二倉式(D), 多倉式(T)

Fittings and accessories meet the same standard and specifications as trunkings 綫槽配件的規格及標准完全遵照及配合電綫槽而制成

Cable trunking 電綫槽

The GY-QJ-C type Cable trunking is a trough-type cable tray suitable for fully enclosed cable installation. It is most suitable for laying computer cables, communication cables, thermocouple cables, and control cables of other highly sensitive systems. It provides effective shielding against interference for control cables and protection for cables in highly corrosive environments. When multiple groups of cable trays are installed parallel at the same height, maintenance and inspection distances should be considered between adjacent cable trays.

GY-QJ-C型電綫槽爲槽式電纜橋架,可以用于全封閉型電纜敷設。它最適合用于敷設計算機電纜、通信電纜、熱電偶電纜及其它高靈敏系統的控制電纜。它對控制電纜的屏蔽干擾和重腐蝕環境中電纜的防護都有較好效果。几組電纜橋架在同一高度平行敷設時,各相鄰電纜橋架之間應考慮維護、檢修距離。




Cable trunking Layout Diagram 電綫槽空間布置示意圖 ▲


Ordering Instructions 訂貨須知

- 1、槽式、托盤式橋架帶蓋板,蓋板厚度按行業標准。
- 2、含相應的螺絲、連接件。
- 3、配件計算方式: 彎通為同等橋架單價的1.4倍, 三 通為同等橋架單價的1.6倍, 四通為同等橋架單價 的1.8倍, 非標配件為同等橋架單價的2倍。
- 4、此價格爲廣東廣羽電纜橋架有限公司出廠價,未含 運輸費,或與當地經銷商洽談。
- 1.Trough-type and tray-type cable trays include covers, with cover thickness complying with industry standards.
- 2.Includes corresponding screws and connecting pieces.
- 3. Fitting calculation method: Elbows are priced at 1.4 times the unit price of the same cable tray, tees at 1.6 times, cross pieces at 1.8 times, and non-standard fittings at 2 times.
- 4. This price is the ex-works price of Guangdong Guangyu Cable Tray Co., Ltd., excluding transportation costs, and may be subject to negotiation with local distributors.


Cable trunking 電綫槽




Snap-Lock Cable trunking 自扣式槽式橋架




Screw Fix Cable trunking 普通直角槽式橋架



Snap-Lock 自鎖蓋型



Screw Fix 螺絲蓋型




Multi-Compartment 分格式

Dimension尺寸 A×B (mm)	THICKNESS 厚度 mm						
50 x 50	1.0	200 x 150	1.2	500 x 100	1.5	900 x 150	2.2
60 x 40	1.0	200 x 200	1.2	500 x 150	1.5	900 x 200	2.2
80 x 50	1.0	250 x 100	1.2	500 x 200	1.5	1000 x 100	2.2
80 x 60	1.0	250 x 150	1.2	600 x 100	2.0	1000 x 150	2.2
90 x 60	1.0	250 x 200	1.2	600 x 150	2.0	1000 x 200	2.2
100 x 50	1.0	300 x 50	1.2	600 x 200	2.0	1100 x 100	2.2
100 x 80	1.0	300 x 100	1.2	700 x 100	2.0	1100 x 150	2.2
100 x 100	1.0	300 x 150	1.2	700 x 150	2.0	1100 x 200	2.2
120 x 100	1.0	300 x 200	1.2	700 x 200	2.0	1200 x 100	2.2
150 x 50	1.0	400 x 50	1.5	800 x 100	2.0	1200 x 150	2.2
150 x 100	1.0	400 x 100	1.5	800 x 150	2.0	1200 x 200	2.2
200 x 50	1.2	400 x 150	1.5	800 x 200	2.0		
200 x 100	1.2	400 x 200	1.5	900 x 100	2.2		


Straight Tray Section 直通 GY-QJ-C-1A




Horizontal Bend 水平彎通GY-QJ-C-1B




Horizontal Tee 水平三通 GY-QJ-C-1C




Horizontal Cross 水平四通 GY-QJ-C-1D



Vertical Up-Bend 垂直上彎 GY-QJ-C-1E




Vertical Down-Bend 垂直下彎 GY-QJ-C-1F



Vertical Up-Right Bend 垂直右上彎通 GY-QJ-C-2G



Vertical Down-Right Bend 垂直右下彎通 GY-QJ-C-2H



Vertical Up-Left Bend 垂直左上彎通GY-QJ-C-2I




Vertical Down-Left Bend 垂直左下彎通 GY-QJ-C-2J




Vertical Tee-Upward Branch 上垂直三通 GY-QJ-C-2K




Vertical Tee-Downward Branch 下垂直三通GY-QJ-C-2L



Vertical Tee with Top Outlet 上邊垂直三通GY-QJ-C-2M




Vertical Tee with Down Outlet 下邊垂直三通GY-QJ-C-2N



Reducer 异徑接口 (Y-Q)-C-20



Vertical Bend with Offset 爬高彎 GY-QJ-C-2P



水平繞彎 GY-QJ-C-2Q Horizontal Double Bend



上角垂直三通 GY-QJ-C-2R Top Corner Vertical Tee



45° Horizontal Elbow 水平45度彎 gy-QJ-C-2S



Connector Plate 連接板 GY-QJ-C-2T



Expansion Joint 伸縮節 GY-QJ-C-2U



With divider(s) 槽式帶隔GY-QJ-C-2V





Cable Tray (Snap-On Perforated Cable Tray) 電纜托盤 (自扣式多乳托盤橋架)

Guangyu Cable Tray Elbows, Tees, and Crosses feature smooth curved designs that completely eliminate scraping points and sharp edges. This significantly reduces cable abrasion throughout the system, extends cable service life, and enhances safety in perforated cable tray applications. The smooth bends facilitate easier cable pulling during installation, reducing deployment difficulty and ergonomic strain. Additionally, they minimize tensile stress on cables and substantially lower pulling resistance.

廣羽托盤橋架彎通、三通與四通,都采用平滑圓弧的結構,徹底消除了刮擦點, 消除尖銳棱角,顯著降低電纜磨損風險,延長電纜壽命,提高有孔托盤橋架系統安全 性。平滑的轉彎使電纜更容易拉動,降低敷設難度和勞動强度,减少對電纜的拉伸應力,顯著降低牽引阻力。



③ Bottom Tray Stiffening Ribs 底板加强筋

底板分布的2條縱向加强筋,凸起筋條可增强底板抗彎剛度,防止被電纜 重壓而導致變形。


Two longitudinal stiffening ribs distributed along the bottom tray enhance bending stiffness through raised profiles, preventing deformation under heavy cable loads.




電纜托盤(多乳托盤式橋架配件)

Straight Tray Section


直通 GY-QJ-P-1A




Horizontal Bend 水平彎通gy-QJ-P-1B




Horizontal Tee 水平三通 GY-QJ-P-1C




Horizontal Cross 水平四通 GY-QJ-P-1D



Vertical Up-Bend 垂直上彎 GY-QJ-P-1E



Vertical Down-Bend 垂直下彎 GY-QJ-P-1F






電纜托盤(多乳托盤式橋架配件)

Vertical Up-Right Bend 垂直右上彎通 GY-QJ-P-2A



Vertical Down-Right Bend 垂古左下絲箔如如如




Vertical Up-Left Bend 垂直左上彎通GY-QJ-P-2C




Vertical Down-Left Bend 垂直左下彎通GY-QJ-P-2D



Vertical Tee-Upward Branch 上垂直三诵 GY-QJ-P-2C




Vertical Tee-Downward Branch 下垂直三通GY-QJ-P-2F






電纜托盤(多乳托盤式橋架配件)

Vertical Tee with Top Outlet 上邊垂直三通 GY-QJ-P-3A




Vertical Tee with Down Outlet




Reducer 异徑接□GY-QJ-P-3C




Vertical Bend with Offset 爬高彎 GY-QJ-P-3D



Horizontal Double Bend 水平繞彎 GY-QJ-P-3E




Top Corner Vertical Tee 上角垂直三通GY-QJ-P-3F






電纜托盤(多乳托盤式橋架配件)

45° Horizontal Elbow 水平45度彎 GY-QJ-P-4A




Connector Plate 連接板 GY-QJ-P-4B



Unstallation Method 安裝方式

① Cable Hanger 吊架



② Support Arm 托臂



③ Frame Hanger 吊框



④ C-shaped Stamped Bracket 幾型托臂





Cable Ladder 電纜梯架

Aesthetically pleasing 外形美觀

Guangyu Cable Tray products feature a unique S-flow curved design that not only enhances structural strength but also maintains an aesthetically pleasing appearance. When assembled with accessories such as elbows and tees, the overall configuration delivers a seamless and visually cohesive effect.

廣羽橋架產品運用了獨特的S流綫形在增加橋架强度之余還不失美觀,且與彎頭三通等產品組裝后整體效果好。




1 Reinforced Rung 横梁加强



② Reinforced Side Rail 梯邊加强

Testing indicates that Guangyu's reinforced side rail provides over 20% greater strength compared to standard right-angled designs of the same thickness. Its superiority is visibly apparent, allowing for clear assessment with the naked eye.

经测试,广羽梯边强度比直角同厚度加强20%以上,且通过肉眼目测就能直观判定优劣。





Cable Ladder 電纜梯架

Straight Tray

直通 GY-QJ-T1-1




Horizontal Bend 水平彎通 GY-QJ-T1-2



Horizontal Tee 水平三通 GY-QJ-T1-3



Horizontal Cross 水平四通 GY-QJ-T1-4




Vertical Up-Bend 垂直上彎 GY-QJ-T1-5



Vertical Down-Bend 垂直下彎 GY-QJ-T1-6



Expansion Joint 伸縮節 GY-QJ-T1-7



Other non-standard elbow customization Welcome to the pictures and samples



Cable Basket (Wire Mesh Cable Tray)

電綫籃(網格橋架系列)

● Extra-Thick Zinc Coating 超厚鋅層 Superior Load Capacity 承重出色 → Wide Range of Options 多種選擇







IEC Certification 國際電工認證



RoHS Compliance RoHS環保檢測



INDEX

產品目録

01–02 Introduction to Cable Basket

03–26 Cable Basket Types

27–32 Cable Basket Connectors

33–36 Wall-Mounting Hardware

37–41 Overhead Suspension Hardware

42–44 Floor-Mounting Hardware

45 Other Accessories

46–58 Cable Basket Installation Guide

電綫籃簡介

電綫籃類型

電綫籃連接配件

電綫籃靠墻安裝配件

電綫籃吊掛安裝配件

電綫籃地裝配件

其他配件

電綫籃安裝指南

Cable Basket (Wire Mesh Cable Tray)

電綫籃(網格橋架系列)

GY-WG Series Mesh Cable Tray is primarily designed for a wide range of applications, including telecommunication equipment rooms, power utilities, and various engineering projects. It is suitable for the laying of all types of cables.

Features:

- Simple and convenient installation.
- Natural ventilation and heat dissipation for cables, reducing energy consumption and conserving energy.
- Easy maintenance and upgrades.

Materials:

 Manufactured using carbon steel (Q235B) or stainless steel (304, 316).


Surface Treatment:

For Carbon Steel:


- Electrogalvanized (EZ) for indoor use.
- Hot-dip galvanized (GC) for outdoor use.
- Powder-coated (DC) with color options available upon customer request.

For Stainless Steel:

· Acid pickling followed by polishing.











50/100/150/200/300/ 400/500/600(mm)




Safe Working Load 安全工作負載


The mesh cable tray product has been tested and certified in accordance with the international standard IEC 61537, including multi-span load testing.

網格橋架產品通過IEC61537 國際標准檢測,多跨距承載測試。

Reference Drawing 參考圖:



Cable basket with 4mm wire diameter and 50mm height, at 1.5m span. 絲徑 4mm 高度 50mm 電纜籃 1.5 米跨距安全工作載荷




Height Width

Cable basket with 5mm wire diameter and 50mm height, at 1.5m span. 絲徑 5mm 高度 50mm 電纜籃 1.5 米跨距安全工作載荷





Cable basket with 6mm wire diameter and 50mm height, at 1.5m span.

絲徑 6mm 高度 50mm 電纜籃 1.5 米跨距安全工作載荷




ieignt 高度	width 寬度	Section view 截面圖
50	50	
50	100	
50	150	
50	200	
50	300	










Cable Basket, 50mm Height 電綫籃 高 50mm

Diameter 鋼絲直徑	Heigh 高			h (W) 度	Lengt 長度		Weight pe 重量(Electro- galvanized	Hot-dip galvanized	Powder coating	304 Stainless Steel	316L Stainless Steel
mm	mm	inck	mm	inch	mm	inch	lb	kg	電鍍鋅	熱鍍鋅	噴塑	304不銹鋼	316L不銹鋼
5	50	2	50	2	3000	10	6.69	3.04	BS15211	BS15212	BS15213	BS15214	BS15215
5	50	2	100	4	3000	10	8.23	3.74	BS15221	BS15222	BS15223	BS15224	BS15225
5	50	2	150	6	3000	10	9.79	4.45	BS15231	BS15232	BS15233	BS15234	BS15235
5	50	2	200	8	3000	10	11.35	5.16	BS15241	BS15242	BS15243	BS15244	BS15245
5	50	2	300	12	3000	10	14.41	6.55	BS15251	BS15252	BS15253	BS15254	BS15255
5	50	2	400	16	3000	10	17.49	7.95	BS15261	BS15262	BS15263	BS15264	BS15265
5	50	2	500	20	3000	10	20.57	9.35	BS15271	BS15272	BS15273	BS15274	BS15275
5	50	2	600	24	3000	10	23.65	10.75	BS15281	BS15282	BS15283	BS15284	BS15285





Height

100

(mm)

↓ Width

100/150/200/300/ 400/500/600(mm)




4/5/6 (mm)

Safe Working Load 安全工作負載

The mesh cable tray product has been tested and certified in accordance with the international standard IEC 61537, including multi-span load testing.


網格橋架產品通過IEC61537 國際標准檢測,多跨距承載測試。

Reference Drawing 參考圖:




Cable basket with 4mm wire diameter and 100mm height, at 1.5m span.

絲徑 4mm 高度 100mm 電纜籃 1.5 米跨距安全工作載荷




Cable basket with 5mm wire diameter and 100mm height, at 1.5m span.

絲徑 5mm 高度 100mm 電纜籃 1.5 米跨距安全工作載荷





Cable basket with 6mm wire diameter and 100mm height, at 1.5m span.

絲徑 6mm 高度 100mm 電纜籃 1.5 米跨距安全工作載荷




Height 高度	Width 寬度	Section view 截面圖
100	100	
100	150	
100	200	
100	300	










Cable Basket, 100mm Height 電綫籃高100mm

Diameter 鋼絲直徑	Heigh 高			h (W) 度	Lengt 長度		Weight pe 重量(Electro- galvanized	Hot-dip galvanized	Powder coating	304 Stainless Steel	316L Stainless Steel
mm	mm	inck	mm	inch	mm	inch	lb	kg	電鍍鋅	熱鍍鋅	噴塑	304不銹鋼	316L不銹鋼
5	100	4	100	4	3000	10	11.35	5.15	BS15321	BS15322	BS15323	BS15324	BS15325
5	100	4	150	6	3000	10	12.9	5.85	BS15331	BS15332	BS15333	BS15334	BS15335
5	100	4	200	8	3000	10	14.44	6.55	BS15341	BS15342	BS15343	BS15344	BS15345
5	100	4	300	12	3000	10	17.53	7.95	BS15351	BS15352	BS15353	BS15354	BS15355
5	100	4	400	16	3000	10	20.61	9.35	BS15361	BS15362	BS15363	BS15364	BS15365
5	100	4	500	20	3000	10	23.7	10.75	BS15371	BS15372	BS15373	BS15374	BS15375
5	100	4	600	24	3000	10	26.79	12.15	BS15381	BS15382	BS15383	BS15384	BS15385







150 (mm) Wid

300/400/ Width 300/600(mm)




4/5/6 (mm)

Safe Working Load 安全工作負載

The mesh cable tray product has been tested and certified in accordance with the international standard IEC 61537, including multi-span load testing.


電綫籃產品通過IEC61537 國際標准檢測,多跨距承載測試。

Reference Drawing 參考圖:




Cable basket with 5mm wire diameter and 150mm height, at 1.5m span.

絲徑 5mm 高度 150mm 電綫籃 1.5 米跨距安全工作載荷





Cable basket with 6mm wire diameter and 150mm height, at 1.5m span.

絲徑 6mm 高度 150mm 電綫籃 1.5 米跨距安全工作載荷



Height 高度	Width 寬度	Section view 截面圖
150	300	
150	400	
150	500	
150	600	








Diameter 鋼絲直徑	Heigh 高	t (H) 度		h (W) 度	Lengt 長度		Weight pe 重量(Electro- galvanized	Hot-dip galvanized	Powder coating	304 Stainless Steel	316L Stainless Steel
mm	mm	inck	mm	inch	mm	inch	lb	kg	電鍍鋅	熱鍍鋅	噴塑	304不銹鋼	316L不銹鋼
4	150	6	300	12	3000	10	13.16	5.98	BS14451	BS14452	BS14453	BS14454	BS14455
4	150	6	400	16	3000	10	15.14	6.88	BS14461	BS14462	BS14463	BS14464	BS14465
4	150	6	500	20	3000	10	17.12	7.78	BS14471	BS14472	BS14473	BS14474	BS14475
4	150	6	600	24	3000	10	19.07	8.67	BS14481	BS14482	BS14483	BS14484	BS14485

Diameter 鋼絲直徑	Heigh 高	t (H) 度		h (W) 度	Lengt 長度		Weight pe 重量(Electro- galvanized	Hot-dip galvanized	Powder coating	304 Stainless Steel	316L Stainless Steel
mm	mm	inck	mm	inch	mm	inch	lb	kg	電鍍鋅	熱鍍鋅	噴塑	304不銹鋼	316L不銹鋼
5	150	6	300	12	3000	10	20.57	9.35	BS15451	BS15452	BS15453	BS15454	BS15455
5	150	6	400	16	3000	10	23.65	10.75	BS15461	BS15462	BS15463	BS15464	BS15465
5	150	6	500	20	3000	10	26.73	12.15	BS15471	BS15472	BS15473	BS15474	BS15475
5	150	6	600	24	3000	10	29.81	13.55	BS15481	BS15482	BS15483	BS15484	BS15485

Diameter 鋼絲直徑	Heigh 高			h (W) 度	Lengt 長度		Weight pe 重量(Electro- galvanized	Hot-dip galvanized	Powder coating	304 Stainless Steel	316L Stainless Steel
mm	mm	inck	mm	inch	mm	inch	lb	kg	電鍍鋅	熱鍍鋅	噴塑	304不銹鋼	316L不銹鋼
6	150	6	300	12	3000	10	29.61	13.46	BS16451	BS16452	BS16453	BS16454	BS16455
6	150	6	400	16	3000	10	34.06	15.48	BS16461	BS16462	BS16463	BS16464	BS16465
6	150	6	500	20	3000	10	38.50	17.50	BS16471	BS16472	BS16473	BS16474	BS16475
6	150	6	600	24	3000	10	42.92	19.51	BS16481	BS16482	BS16483	BS16484	BS16485

。 連接

Cable Basket Buckle Assembly 電綫籃卡扣組件



The buckle assembly consists of 1 outer clip, 1 inner clip, 1 M6×20 carriage bolt, and 1 M6 flanged nut sleeve. 卡扣組件是由1個外卡,1個內卡,1個M6×20馬車螺栓和1個 M6 法蘭面螺母套組成。

- ▼ The buckle assembly is compatible with all Cable Basket connections. 卡扣組件適用于所有電綫籃槽體連接。
- \$ The buckle assembly is sold separately. 卡扣組件單獨出售。



1.M6×20 Carriage Bolt

1.M6×20 馬車螺栓

2 0...+

2.Outer Clip 2.外卡

3.Inner Clip

3.內卡

4.M6 Flange Nut

4.M6 法兰螺母


Component List 組件清單

Product Name 產品名稱	9	Electro-galvanized 電鍍鋅	Hot-dip galvanized 熱鍍鋅	Powder coating 噴塑	304 Stainless Steel 304不銹鋼	316L Stainless Steel 316L不銹鋼
Buckle Assembly	卡扣組件	BFK011	BFK012	BFK013	BFK014	BFK015
M6×20 Carriage Bolt	馬車螺栓	T011	-	_	T014	T015
Outer Clip	外卡	BF011	BF012	BF013	BF014	BF015
Inner Clip	內卡	BF021	BF022	BF023	BF024	BF025
M6 Flange Nut	法蘭螺母	T021	-	_	T024	T025

Scope of Application and Usage Quantity 適用範圍及使用量

H (50–100–150)mm	50mm	100-200mm	300-600mm
Side Installation Quantity 側邊安裝數量	2 sets of Cable Basket Buckle Assembly 2 套電綫籃卡扣組件	2 sets of Cable Basket Buckle Assembly 2 套電綫籃卡扣組件	2 sets of Cable Basket Buckle Assembly 2 套電綫籃卡扣組件
Bottom Installation Quantity 底部安裝數量	_	1 sets of Cable Basket Buckle Assembly 1 套電綫籃卡扣組件	2 sets of Cable Basket Buckle Assembly 2 套電綫籃卡扣組件

Other Application Fields 其他應用範疇



。 連接


Cable Basket Stiffening Bar Assembly 電綫籃加强條組件



Cable Basket stiffening bar assembly consists of 1 grid stiffening bar, 3 inner clips, 3 M6×20 carriage bolts, and 3 M6 flange nuts. 電綫籃加强條組件由1個網格加强條,3個內卡,3個M6×20馬車螺栓和3個M6法蘭螺母組成。

- ✓ The cable basket reinforcement bar assembly is used for horizontal linear connections of channels.
 電綫籃加强條組件應用于槽體的水平直綫連接。
- The cable basket reinforcement bar assembly is sold separately. 電綫籃加强條組件單獨出售。







Reinforcement Bar Assembly 電綫籃加强條組件



Reinforcement Bar 電綫籃加强條

Component List 組件清單


Product Name 產品名稱	Electro-galvanized 電鍍鋅	Hot-dip galvanized 熱鍍鋅	Powder coating 噴塑	304 Stainless Steel 304不銹鋼	316L Stainless Steel 316L不銹鋼
Cable Basket Reinforcement Bar Assembly 電綫籃加强條組件	BFK021	BFK022	BFK023	BFK024	BFK025
Cable Basket Reinforcement Bar 電綫籃加强條	BF031	BF032	BF033	BF034	BF035
Cable Basket Buckle Assembly 電綫籃卡扣組件	BFK011	BFK012	BFK013	BFK014	BFK015

Scope of Application and Usage Quantity 適用範圍及使用量

H (50–100–150)mm	50mm	100-200mm	300-600mm
Side Installation Quantity 側邊安裝數量	2 sets of Cable Basket Reinforcement Bar Assembly 2 套電綫籃加强條組件	2 sets of Cable Basket Reinforcement Bar Assembly 2 套電綫籃加强條組件	2 sets of Cable Basket Reinforcement Bar Assembly 2 套電綫籃加强條組件
Bottom Installation Quantity 底部安裝數量	_	1 sets of Cable Basket Buckle Assembly 1 套電綫籃卡扣組件	2 sets of Cable Basket Buckle Assembly 2 套電綫籃卡扣組件

Other Application Fields 其他應用範疇





連接

Quick-connect clip forCable Basket 電綫籃快速連接條



The quick-connect clip for cable basket trays facilitates tool-free, screwless installation, enabling rapid and secure splicing of tray sections. When used with matching clip components, the system is also capable of creating junctions that meet high load-bearing requirements.

電綫籃快速連接條拼接是免螺絲安裝, 能快速的連接槽體, 牢固可靠, 配合卡扣組件使用也能適應于承重要求高的槽體對接。

- ✓ The quick-connect clip for cable basket trays is designed for the horizontal, straight-line joining of troughs with matching widths.
 電綫籃快速連接條應用于同寬度槽體的水平直綫連接。
- \$ It is sold separately. 電纜籃快速鏈接條單獨出售。

Cable Basket Clip Assembly 電綫籃卡扣組件





Quick-Connect Clip for Cable Basket Tray 電綫籃快速連接條

Component List 組件清單

Product Name 產品名稱	Electro-galvanized 電鍍鋅	Hot-dip galvanized 熱鍍鋅	Powder coating 噴塑	304 Stainless Steel 304不銹鋼	316L Stainless Steel 316L不銹鋼
Quick-Connect Clip for Cable Basket Tray 電綫籃快速連接條	BF041	BF042	BF043	BF044	BF045
Cable Basket Clip Assembly 電綫籃卡扣組件	BFK011	BFK012	BFK013	BFK014	BFK015


Scope of Application and Usage Quantity 適用範圍及使用量







L-Shaped Connecting Fitting Kit for Cable Basket Tray 電綫籃L 形連接件組件



The Cable Tray L-Shaped Corner Connector Kit includes: 1 L-Shaped Fitting,2 Inner Clips,2 M6 x 20 Hex Flange Bolts,2 M6 Hex Flange Nuts 電綫籃L形連接件組件是有1個L形連接件,2個內卡,2個M6×20六角法蘭螺栓和 2個 M6 六角法蘭螺母組成。

- ✓ The L-Shaped Connecting Fitting Kit for Cable Basket Tray is designed for creating horizontal T-shaped junctions and 90-degree turns between tray sections.
 電綫籃L形連接件組件用于電綫籃槽體的水平T形連接和水平 90°直角轉彎時的直角連接。
- \$ This connector kit is sold separately. 電綫監L 形連接件組件單獨出售。







Cable Basket Clip Kit 電綫籃卡扣組件


L-Shaped Connecting Kit 電綫籃L形連接件組件


L-Shaped Connector 電綫籃L形連接件


Component List 組件清單

Product Name 產品名稱	Electro-galvanized 電鍍鋅	Hot-dip galvanized 熱鍍鋅	Powder coating 噴塑	304 Stainless Steel 304不銹鋼	316L Stainless Steel 316L不銹鋼
Cable Basket Clip Kit 電綫籃卡扣組件	BFK051	BFK052	BFK053	BFK054	BFK055
L-Shaped Connecting Kit 電綫籃L 形連接件組件	BF051	BF052	BF053	BF054	BF055
L-Shaped Connector 電綫籃L形連接件	BFK011	BFK021	BFK031	BFK041	BFK051


Scope of Application and Usage Quantity 適用範圍及使用量







The screwless latch-type clip for cable basket 電綫籃無栓卡扣



The latch-type clip for cable basket trays enables tool-free, screwless installation for securing the bottom connection in horizontal straight-run applications, ensuring quick and easy assembly.

電綫籃無栓卡扣是免螺絲安裝,用于電綫籃水平直綫連接時底部的連接,安裝快捷方便。


\$ The screwless latch-type clip for cable basket trays is sold separately. 電綫籃無栓卡扣單獨出售。



The screwless latch-type clip for cable basket 電綫籃無栓卡扣

Product Name	Electro-galvanized	Hot-dip galvanized	Powder coating	304 Stainless Steel	316L Stainless Steel
產品名稱	電鍍鋅	熱鍍鋅	噴塑	304不銹鋼	316L不銹鋼
网格无栓卡扣	BF071	BF072	BF073	BF074	BF075

R140 Connector Kit for Cable Basket 電綫監R140 連接件組件



The R140 Cable Basket Connector Assembly consists of 1 R140 connector. 4 M6×20 carriage bolts, 4 lock washers, and 4 M6 flange nuts.

The R140 Cable Basket Connector Assembly is used for horizontal 90degree arc turns in grid-style cable trays, ensuring a large-radius bend to meet the requirements for cable routing.

電綫籃 R140 連接件組件是由1個 R140 連接件, 4個M6×20馬 車螺栓,4個內卡,4個M6法蘭螺母組成。

電綫籃 R140 連接件組件用于網格的水平 90°圓弧轉彎, 能保 證綫纜的大圓弧彎曲要求。

The R140 Cable Tray Connector Assembly is sold separately. 電纜籃R140連接件組件單獨出售。








Center Latch Assembly 中心卡扣組件

R140 Connector Assembly R140 連接件組件

R140 Connector R140 連接件

Product Name 產品名稱	Electro-galvanized 電鍍鋅	Hot-dip galvanized 熱鍍鋅	Powder coating 噴塑	304 Stainless Steel 304不銹鋼	316L Stainless Steel 316L不銹鋼
R140 Connector H50 Assembly R140 連接件 H50 組件	BFK111	BFK112	BFK113	BFK114	BFK115
R140 Connector H100 Assembly R140 連接件 H100 組件	BFK121	BFK122	BFK123	BFK124	BFK125
R140 Connector H150 Assembly R140連接件 H150 組件	BFK131	BFK132	BFK133	BFK134	BFK135
R140 Connector H50 R140 連接件 H50	BF111	BF112	BF113	BF114	BF115
R140 Connector H100 R140 連接件 H100	BF121	BF122	BF123	BF124	BF125
R140 Connector H150 R140連接件 H150	BF131	BF132	BF133	BF134	BF135
Clip Assembly 卡扣組件	BFK011	BFK012	BFK013	BFK014	BFK015

R300 Connector Kit for Cable Basket 電綫監R300 連接件組件



The R300 Cable Basket Connector Assembly consists of 1 R300 connector, 4 M6×20 carriage bolts, 4 internal tooth lock washers, and 4 M6 flange nuts. This assembly is used for 90-degree horizontal radius turns in Cable Basket, ensuring a large bending radius to meet the required cable routing specifications.

電綫籃 R300 連接件組件是由 1個 R300 連接件, 4 個 M6×20馬 車螺栓,4個內卡,4個M6法蘭螺母組成。

電綫籃R300連接件組件用于網格的水平90°圓弧轉彎, 綫纜的大圓弧彎曲要求。

The R300 Cable Tray Connector Assembly is sold separately. 電纜籃R300連接件組件單獨出售。



Center Latch Assembly





R300 Connector Assembly 中心卡扣組件 R300 連接件組件

R300 Connector R300 連接件

Product Name 產品名稱	Electro-galvanized 電鍍鋅	Hot-dip galvanized 熱鍍鋅	Powder coating 噴塑	304 Stainless Steel 304不銹鋼	316L Stainless Steel 316L不銹鋼
R300 Connector H50 Assembly R300 連接件 H50 組件	BFK141	BFK142	BFK143	BFK144	BFK145
R300 Connector H100 Assembly R300 連接件 H100 組件	BFK151	BFK152	BFK153	BFK154	BFK155
R300 Connector H150 Assembly R300 連接件 H150 組件	BFK161	BFK162	BFK163	BFK164	BFK165
R300 Connector H50 R300 連接件 H50	BF141	BF142	BF143	BF144	BF145
R300 Connector H100 R300 連接件 H100	BF151	BF152	BF153	BF154	BF155
R300 Connector H150 R300 連接件 H150	BF161	BF162	BF163	BF164	BF165

Radius Baffle for Cable Basket 電綫監圓弧擋板



The Cable Basket radius baffle is formed from 0.8mm thick metal sheet, which can be bent to any required arc radius and clipped onto the side edges of the Cable Basket.

It is used to provide a smooth transitional arc at directional turns in the Cable Basket, ensuring an adequate cable bending radius. The baffle features quick and tool-free installation, requiring only a few seconds to secure. It is typically employed in applications where high loadbearing capacity is not a critical requirement.

電綫籃圓弧擋板是由 0.8MM 厚金屬薄板彎曲成任意圓弧卡

到電綫籃兩頭的側邊上。電綫籃圓弧擋板用于電綫籃轉彎連接時的圓弧過渡,保證圓弧彎曲半徑,安裝方便快捷只需几秒鐘,一般用于對承 重要求不高的連接上。

The Cable Basket Radius Baffle is sold separately. 電纜籃圓弧擋板單獨出售。








Radius Baffle (Flat Pattern) 圓弧擋板 (展開)

Product Name 產品名稱	Electro-galvanized 電鍍鋅	Hot-dip galvanized 熱鍍鋅	Powder coating 噴塑	304 Stainless Steel 304不銹鋼	316L Stainless Steel 316L不銹鋼
Radius Baffle H50 圓弧擋板 H50	BF171	BF172	BF173	BF174	BF175
Radius Baffle H100 圓弧擋板 H100	BF181	BF182	BF183	BF184	BF185
Radius Baffle H150 圓弧擋板 H150	BF191	BF192	BF193	BF194	BF195

Mid-Position Latch Assembly for Cable Basket 電綫籃中卡扣組件



The center latch assembly consists of 2 center latches, 1 M6×20 carriage bolt, and 1 M6 hex flange nut.

中心卡扣組件是由2個中心卡扣,1個M6×20馬車螺栓和1個M6六 角法蘭螺母組成。

The Cable Basket center latch assembly can be used for grid connection, allowing the Cable Basket troughs to be connected at different horizontal turning angles. When used with a bolt and a plastic conduit, it can also serve as a hanging support.

電綫籃中心卡扣組件可用于網格連接,可使電綫籃槽體連接成不同的水平轉彎角度,配合螺杆和塑料管可用于吊掛支撑。


The Cable Basket Center Latch Assembly is sold separately. 電纜籃中心卡扣組件單獨出售。




Center Latch Assembly 中心卡扣組件

Product Name	Electro-galvanized	Hot-dip galvanized	Powder coating	304 Stainless Steel	316L Stainless Steel
產品名稱	電鍍鋅	熱鍍鋅	噴塑	304不銹鋼	316L不銹鋼
Center Latch 中心卡扣	BF061	BF062	BF063	BF064	BF065

Other Application Fields 其他應用範疇





HOLE CABLE TRAY 網篩標架























With built-in connector連駁款

Without built-in connector平邊款

		,—,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	•	1 237			
Cable Tray size	Dimonoion	尺寸(mm)	Calination of Charle	Model number 型號			
電纜托盤(mm)	A	B B	Galvanised Steel - 镀锌钢	Hot-dipped Galvanised 熱浸鋅	Stainless Steel SS304 不銹鋼 SS304	Stainless Steel 316 不銹鋼 SS316	
50	50	13	SG2T12	SG2T12H	SG2T12S	SG2T12X	
75	75	13	SG3T12	SG3T12H	SG3T12S	SG3T12X	
100	100	13	SG4T12	SG4T12H	SG4T12S	SG4T12X	
150	150	13	SG6T12	SG6T12H	SG6T12S	SG6T12X	
200	200	13	SG8T15	SG8T15H	SG8T15S	SG8T15X	
300	300	20	SG12T15	SG12T15H	SG12T15S	SG12T15X	
400	400	20	SG16T15	SG16T15H	SG16T15S	SG16T15X	
500	500	20	SG20T20	SG20T20H	SG20T20S	SG20T20X	
600	600	20	SG24T20	SG24T20H	SG24T20S	SG24T20X	
700	700	20	SG28T20	SG28T20H	SG28T20S	SG28T20X	
800	800	20	SG32T20	SG32T20H	SG32T20S	SG32T20X	
900	900	20	SG36T20	SG36T20H	SG36T20S	SG36T20X	

GY-QJ-WS-2網篩橋架 Return Flange Type 勾折邊式




With built-in connector 連駁款


Without built-in connector 平邊款


							2371
Cable Tray size	Dimensio	n Rt	-(mm)	Galvanised Steel		Model number 型號	ŧ
电缆托盘 (mm)	A	В	C	鍍鋅鋼	Hot-dipped Galvanised 熱浸鋅	Stainless Steel SS304 不銹鋼 SS304	Stainless Steel 316 不銹鋼 SS316
50	50	20	13	SG2T12	SG2T12H	SG2T12S	SG2T12X
75	75	20	13	SG3T12	SG3T12H	SG3T12S	SG3T12X
100	100	20	13	SG4T12	SG4T12H	SG4T12S	SG4T12X
150	150	20	13	SG6T12	SG6T12H	SG6T12S	SG6T12X
200	200	20	13	SG8T15	SG8T15H	SG8T15S	SG8T15X
300	300	20	20	SG12T15	SG12T15H	SG12T15S	SG12T15X
400	400	20	20	SG16T15	SG16T15H	SG16T15S	SG16T15X
500	500	20	20	SG20T20	SG20T20H	SG20T20S	SG20T20X
600	600	20	20	SG24T20	SG24T20H	SG24T20S	SG24T20X
700	700	20	20	SG28T20	SG28T20H	SG28T20S	SG28T20X
800	800	20	20	SG32T20	SG32T20H	SG32T20S	SG32T20X
900	900	20	20	SG36T20	SG36T20H	SG36T20S	SG36T20X

GY-QJ-WS-1 網篩橋架 Fittings and accessories 托盤曲及配件

90°Mitre bend 90°斜角彎曲








Flat Bend 正曲型


Internal Bend 内曲型


External Bend 外曲型

Suitable for tray size		Dimen	sion 尺 ⁻	寸(mm)		Model: Single Flange 单折边式(SG),Return Flange 勾折边式(RG		
適合托盤尺寸 (mm)	А	В	С	D	Е	Flat Bend 正曲型	Internal Bend 內曲型	External Bend 外曲型
50	50	125	106	150	106	SG/RG2.1T12H	SG/RG2.2T12H	SG/RG2.4BT12H
75	75	150	106	150	106	SG/RG3.1T12H	SG/RG3.2T12H	SG/RG3.4BT12H
100	100	175	106	150	106	SG/RG4.1T12H	SG/RG4.2T12H	SG/RG4.4BT12H
150	150	225	106	150	106	SG/RG6.1T12H	SG/RG6.2T12H	SG/RG6.4BT12H
200	200	300	141	175	106	SG/RG8.1T16H	SG/RG8.2T16H	SG/RG8.4BT16H
300	300	400	141	225	106	SG/RG12.1T16H	SG/RG12.2T16H	SG/RG12.4BT16H
400	400	525	177	275	106	SG/RG16.1T16H	SG/RG16.2T16H	SG/RG16.4BT16H
500	500	625	177	275	106	SG/RG20.1T20H	SG/RG20.2T20H	SG/RG20.4BT20H
600	600	750	212	325	106	SG/RG24.1T20H	SG/RG24.2T20H	SG/RG24.4BT20H
700	700	850	212	325	106	SG/RG24.1T20H	SG/RG24.2T20H	SG/RG24.4BT20H
800	800	950	212	325	106	SG/RG28.1T20H	SG/RG28.2T20H	SG/RG28.4BT20H
900	900	1050	212	325	106	SG/RG32.1T20H	SG/RG32.2T20H	SG/RG32.4BT20H

135° Mitre bend 135° 斜角彎曲








Flat Bend 正曲型

Internal Bend 内曲型

External Bend 外曲型


Suitable for tray size	D	imensior	カス寸(mi	m)	Model: Single Flange 單折邊式 (SG) , Return Flange 勾折邊式 (Re			
適合托盤尺寸(mm)	Α	В	С	D	Flat Bend 正曲型	Internal Bend 內曲型	External Bend 外曲型	
50	50	95	75	75	SG/RG2.1AT12H	SG/RG2.11BT12H	SG/RG2.11CT12H	
75	75	106	75	75	SG/RG3.1AT12H	SG/RG3.11BT12H	SG/RG3.11CT12H	
100	100	116	75	75	SG/RG4.1AT12H	SG/RG4.11BT12H	SG/RG4.11CT12H	
150	150	137	75	75	SG/RG6.1AT12H	SG/RG6.11BT12H	SG/RG6.11CT12H	
200	200	158	75	75	SG/RG8.1AT16H	SG/RG8.11BT16H	SG/RG8.11CT16H	
300	300	224	100	100	SG/RG12.1AT16H	SG/RG12.11BT16H	SG/RG12.11CT16H	
400	400	366	200	200	SG/RG16.1AT16H	SG/RG16.11BT16H	SG/RG16.11CT16H	
500	500	407	200	200	SG/RG20.1AT20H	SG/RG20.11BT20H	SG/RG20.11CT20H	
600	600	548	300	300	SG/RG24.1AT20H	SG/RG24.11BT20H	SG/RG24.11CT20H	
700	700	590	300	300	SG/RG24.1AT20H	SG/RG28.11BT20H	SG/RG28.11CT20H	
800	800	631	300	300	SG/RG28.1AT20H	SG/RG32.11BT20H	SG/RG32.11CT20H	
900	900	673	300	300	SG/RG32.1AT20H	SG/RG36.11BT20H	SG/RG36.11CT20H	

GY-QJ-WS-1 網篩橋架 Fittings and accessories 橋架和配件



Suitable for tray size	Dir	nension 尺寸(n	nm)	Model: Single Flange 單折邊式 (SG)
適用電纜托盤尺寸 (mm)	A	В	С	Return Flange 勾折邊式(RG)
50	50	125	200	SG/RG2.3T12H
75	75	150	225	SG/RG3.3T12H
100	100	175	250	SG/RG4.3T12H
150	150	225	300	SG/RG6.3T12H
200	200	300	400	SG/RG8.3T16H
300	300	400	500	SG/RG12.3T16H
400	400	525	650	SG/RG16.3T16H
500	500	625	750	SG/RG20.3T20H
600	600	750	900	SG/RG24.3T20H
700	700	850	1000	SG/RG28.3T20H
800	800	950	1100	SG/RG32.3T20H
900	900	1050	1200	SG/RG36.3T20H


Mitre Cross 斜切四通





Suitable for tray size	Dimension	尺寸(mm)	Model: Single Flange 單折邊式 (SG)
適用電纜托盤尺寸 (mm)	Α	В	Return Flange 勾折邊式(RG)
50	50	200	SG/RG2.5T12H
75	75	225	SG/RG3.5T12H
100	100	250	SG/RG4.5T12H
150	150	300	SG/RG6.5T12H
200	200	400	SG/RG8.5T16H
300	300	500	SG/RG12.5T16H
400	400	650	SG/RG16.5T16H
500	500	750	SG/RG20.5T20H
600	600	900	SG/RG24.5T20H
700	700	1000	SG/RG28.5T20H
800	800	1100	SG/RG32.5T20H
900	900	1200	SG/RG36.5T20H

GY-QJ-WS-1 網篩橋架 Fittings and accessories 橋架和配件

Reducer 异徑接頭








Equal 正接


Left 左邊

Right 右邊

Suitable for tray size	Din	nension 尺寸(mm	1)	Model: Single Flange 單折邊式 (SG)
適用電纜托盤尺寸 (mm)	Α	В	С	Return Flange 勾折邊式(RG)
75-50	150	50	75	SG/RG3.6T12H
100-75	150	75	100	SG/RG4.6T12H
150-100	200	100	150	SG/RG6.6T12H
150-75	200	75	150	SG/RG8.6T12H
200-150	200	150	200	SG/RG8.6T16H
200-100	200	100	200	SG/RG8.6T16H
300-200	300	200	300	SG/RG12.6T16H
300-150	300	150	300	SG/RG12.6T16H
400-300	400	300	400	SG/RG16.6T16H
600-400	500	400	600	SG/RG24.6T20H

Cable tray connector 連接件






Common Type 普通型

Tray side connector 托盤側連接

Cable Tray size	Dimension 尺寸(mm)	Galvanised Steel	Model number			
電纜托盤 (mm) A	鍍鋅鋼	Hot-dipped Galvanised 熱浸鋅	Stainless Steel SS304 不銹鋼 SS304	Stainless Steel 316 不銹鋼 SS316		
50	40	SGC2	SGC2H	SGC2S	SGC2X	
75	65	SGC3	SGC3H	SGC3S	SGC3X	
100	90	SGC4	SGC4H	SGC4S	SGC4X	
150	140	SGC6	SGC6H	SGC6S	SGC6X	
200	190	SGC8	SGC8H	SGC8S	SGC8X	
300	290	SGC12	SGC12H	SGC12S	SGC12X	
400	390	SGC16	SGC16H	SGC16S	SGC16X	
500	490	SGC20	SGC20H	SGC20S	SGC20X	
600	590	SGC24	SGC24H	SGC24S	SGC24X	
900	890	SGC36	SGC36H	SGC36S	SGC36X	

Fittings and accessories

橋架和配件





Quality Management System Certificate Guangdong Guangyu Cable Tray Co., Ltd

Certificate No.:1952024Q0187R0S

Unified Social Credit Code:9144030031200123XE

Registration Address: Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City,

Guangdong Province

Business Address: Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City,

Guangdong Province

Management system conforms to the standard:GB/T 19001-2016/ISO 9001:2015

The certificate is valid for the scope: Sales of cable tray, wire mesh cable tray, fiber cable tray,

aluminum alloy cable tray, cable-fixer, and connectors

Date of Issuance: Mar.11,2024 Date of Expiry:Mar.10,2027

Note: After the issuance of this certificate, it will remain valid only if the certified organization accepts

surveillance audit at regular intervals within the validity period and is audited to be qualified.







中国认可 国际互认 管理体系 MANAGEMENT SYSTEM CNAS C195-M

^{密发人:}(Wifned 名

The effectiveness of the certificate is subject to the scanned content of the QR code on the right.

Beijing Kun Biao Certification & Inspection Co., Ltd.

Website: www.bjkbrz.com

Meanwhile, you can check on CNCA website: www.cnca.gov.cn

Beijing Kun Biao Certification & Inspection Co., Ltd.

Address: Rooms 3003 and 3005, Floor 26, Building 601, Wangjingyuan,

Chaoyang District, Beijing.

Postcode: 100102 Tel: 010-84631655/84622396 Fax: 010-64780891





Environmental Management System Certificate Guangdong Guangyu Cable Tray Co., Ltd

Certificate No.:1952024E0088R0S

Unified Social Credit Code:9144030031200123XE

Registration Address: Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City,

Guangdong Province

Business Address: Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City,

Guangdong Province

Management system conforms to the standard: GB/T 24001-2016/ISO 14001:2015

The certificate is valid for the scope: Environmental management activities related to the sales of cable

tray, wire mesh cable tray, fiber cable tray, aluminum alloy cable tray,

cable-fixer, and connectors

Date of Issuance: Mar.11,2024 Date of Expiry:Mar.10,2027

Note: After the issuance of this certificate, it will remain valid only if the certified organization accepts

surveillance audit at regular intervals within the validity period and is audited to be qualified.







中国认可 国际互认 管理体系 MANAGEMENT SYSTEM CNAS C195-M

签发人: 《Whywal

The effectiveness of the certificate is subject to the scanned content of the QR code on the right.

Beijing Kun Biao Certification & Inspection Co., Ltd.

Website: www.bjkbrz.com

Meanwhile, you can check on CNCA website: www.cnca.gov.cn

Beijing Kun Biao Certification & Inspection Co., Ltd.

Address: Rooms 3003 and 3005, Floor 26, Building 601, Wangjingyuan,

Chaoyang District, Beijing.

Postcode: 100102 Tel: 010-84631655/84622396 Fax: 010-64780891





Occupational Health Safety Management System Certificate Guangdong Guangyu Cable Tray Co., Ltd

Certificate No.:1952024S0079R0S

Unified Social Credit Code:9144030031200123XE

Registration Address: Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City,

Guangdong Province

Business Address: Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City,

Guangdong Province

Management system conforms to the standard:GB/T 45001-2020/ISO 45001:2018

The certificate is valid for the scope: Occupational health and safety management activities related to

the sales of cable tray, wire mesh cable tray, fiber cable tray, aluminum alloy cable tray, cable-fixer, and connectors

Date of Issuance: Mar.11,2024 Date of Expiry:Mar.10,2027

Note: After the issuance of this certificate, it will remain valid only if the certified organization accepts

surveillance audit at regular intervals within the validity period and is audited to be qualified.







中国认可 国际互认 管理体系 MANAGEMENT SYSTEM CNAS C195-M

签发人:

The effectiveness of the certificate is subject to the scanned content of the QR code on the right.

Beijing Kun Biao Certification & Inspection Co., Ltd.

Website: www.bjkbrz.com

Meanwhile, you can check on CNCA website: www.cnca.gov.cn

Beijing Kun Biao Certification & Inspection Co., Ltd.

Address: Rooms 3003 and 3005, Floor 26, Building 601, Wangjingyuan,

Chaoyang District, Beijing.

Postcode: 100102 Tel: 010-84631655/84622396 Fax: 010-64780891



 Certificate Number
 UL-US-2233269-0

 Report Reference
 E521500-20220909

Date 15-Sep-2022

Issued to: Guangdong Guangyu cable tray Co., Ltd

Room 102, No. 11, Daojiao North Ring West Road, Daojiao

Town Dongguan, Guangdong 523170

China

This is to certify that representative samples of

CYNW - Cable Trays, Metal

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the

Standard(s) indicated on this Certificate.

Standard(s) for Safety: NEMA VE 1, 6th Ed., Issue Date: 2017-07-14

Additional Information: See the UL Online Certifications Directory at

https://iq.ulprospector.com for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.





 Certificate Number
 UL-US-2233269-0

 Report Reference
 E521500-20220909

Date 15-Sep-2022

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Model	Category Description		
100-LJP-YJ	Accessories		
50-50-LJP-YJ	Accessories		
50-50-LJP-ZJ	Accessories		
GDQJ-T-1-2010-001	Solid Channel Cable Tray		
GDQJ-T-1-2010-002	Solid Channel Cable Tray		
GDQJ-T-1-2010-003	Solid Channel Cable Tray		
GDQJ-T-1-2010-004	Solid Channel Cable Tray		
GDQJ-T-1-2010-005	Solid Channel Cable Tray		
GDQJ-T-1-2010-006	Solid Channel Cable Tray		



Bruce Mahrenholz, Director North American Certification Program

UL LLC



Certificate Number UL-CA-2232395-0
Report Reference E521500-20220909

Date 15-Sep-2022

Issued to: Guangdong Guangyu cable tray Co., Ltd

Room 102, No. 11, Daojiao North Ring West Road, Daojiao

Town Dongguan, Guangdong 523170

China

This is to certify that representative samples of

CYNW7 - Cable Trays, Metal Certified for Canada See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the

Standard(s) indicated on this Certificate.

Standard(s) for Safety: CSA C22.2 NO. 126.1-17, 4th Ed., Issue Date: 2017-07-01

Additional Information: See the UL Online Certifications Directory at

https://ig.ulprospector.com for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.





Certificate Number UL-CA-2232395-0
Report Reference E521500-20220909

Date 15-Sep-2022

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Model	Category Description		
100-LJP-YJ	Accessories		
50-50-LJP-YJ	Accessories		
50-50-LJP-ZJ	Accessories		
GDQJ-T-1-2010-001	Solid Channel Cable Tray		
GDQJ-T-1-2010-002	Solid Channel Cable Tray		
GDQJ-T-1-2010-003	Solid Channel Cable Tray		
GDQJ-T-1-2010-004	Solid Channel Cable Tray		
GDQJ-T-1-2010-005	Solid Channel Cable Tray		
GDQJ-T-1-2010-006	Solid Channel Cable Tray		

Bamely

Bruce Mahrenholz, Director North American Certification Program

UL LLC



File E521500 Project 4789892756

September 9, 2022 REPORT

on

CABLE TRAYS, METAL

Under the CLASSIFICATION PROGRAM

GUANGDONG GUANGYU CABLE TRAY CO., LTD. Guangdong, 523170, China

Copyright © 2022 UL LLC

UL LLC authorizes the above named company to reproduce this Report only for purposes as described in the Conclusion, provided it is reproduced in its entirety.

Certificate of Compliance

No. 4A220829.GGCQU06

Test Report / Technical Construction File no. BKC22082660HS

Certificate's Guangdong Guangyu Cable Tray Co., Ltd. Room 102, No. 11, Daojiao North Ring West Road, Daojiao

Town, Dongguan City, Guangdong Province

Certification ECM Mark:

Holder:



Product: Sheet metal wire frame Model(s): GY-BJXJ-01, GY-BJXJ-01X.

Verification to: Standard:

EN 61537:2007

related to CE Directive(s): 2014/35/EU (Low Voltage)

Remark: This document is a voluntary third-party EC verification where the manufacturer voluntarily decides to have its documents concerning the above-mentioned product(s) verified. Ente Certificazione Macchine Srl confirms that the documentation provided by the manufacturer and immediately returned to it as containing sensitive data, meets the essential requirements of the above-mentioned directives and the requirements of the ECM certification mark. This document cannot replace the EC Declaration of Conformity. The above conformity mark may be affixed to the documentation in accordance with the ECM Regulation on its issue and use.

Additional information and clarification on marking:

The presence of the EC symbol shown on the left is to demonstrate the type of activity carried out.



The manufacturer must carry out the EC marking process before placing the product(s) on the market, and if the product(s) so requires, it must be submitted to a notified body. This document has been issued on the basis of the Voluntary Certificate Issuing Regulation number RCC ECM rev. 0 and the Voluntary ECM Marking Regulation for product certification. RG01_ECM rev.3 both available at www.entecerma.it

Issuance date: 29 August 2022 Expiry date: 28 August 2027

Reviewer

Technical expert Amanda Payne

Approver Ente Certificazione Macchine Legal Representative Luca Bedonni



Certificate of Compliance

No. 4A220829.GGCQU07

Test Report / Technical Construction File no. BKC22082661HS

Certificate's Guangdong Guangyu Cable Tray Co., Ltd. Room 102, No. 11, Daojiao North Ring West Road, Daojiao

Town, Dongguan City, Guangdong Province

Certification ECM Mark:



Product: Optical fiber wire frame Model(s): GY-GQXJ-04, GY-GQXJ-04X.

Verification to: Standard:

EN 61537:2007

related to CE Directive(s): 2014/35/EU (Low Voltage)

Remark: This document is a voluntary third-party EC verification where the manufacturer voluntarily decides to have its documents concerning the above-mentioned product(s) verified. Ente Certificazione Macchine Srl confirms that the documentation provided by the manufacturer and immediately returned to it as containing sensitive data, meets the essential requirements of the above-mentioned directives and the requirements of the ECM certification mark. This document cannot replace the EC Declaration of Conformity. The above conformity mark may be affixed to the documentation in accordance with the ECM Regulation on its issue and use.

Additional information and clarification on marking:

The presence of the EC symbol shown on the left is to demonstrate the type of activity carried out.



The manufacturer must carry out the EC marking process before placing the product(s) on the market, and if the product(s) so requires, it must be submitted to a notified body. This document has been issued on the basis of the Voluntary Certificate Issuing Regulation number RCC_ECM rev. 0 and the Voluntary ECM Marking Regulation for product certification. RG01_ECM rev.3 both available at www.entecerma.it

Issuance date: 29 August 2022 Expiry date: 28 August 2027

Reviewer

Technical expert
Amanda Payne

Approver
Ente Certificazione Macchine
Legal Representative
Luca Bedonni



Certificate of Compliance

No. 4A220829.GGCQU08

Test Report / Technical Construction File no. BKC22082662HS

Certificate's Guangdong Guangyu Cable Tray Co., Ltd. Room 102, No. 11, Daojiao North Ring West Road, Daojiao

Town, Dongguan City, Guangdong Province

Certification ECM Mark:



Product: Grid frame

Model(s): GY-WGXJ-02, GY-WGXJ-02X.

Verification to: Standard:

EN 61537:2007

related to CE Directive(s): 2014/35/EU (Low Voltage)

Remark: This document is a voluntary third-party EC verification where the manufacturer voluntarily decides to have its documents concerning the above-mentioned product(s) verified. Ente Certificazione Macchine Srl confirms that the documentation provided by the manufacturer and immediately returned to it as containing sensitive data, meets the essential requirements of the above-mentioned directives and the requirements of the ECM certification mark. This document cannot replace the EC Declaration of Conformity. The above conformity mark may be affixed to the documentation in accordance with the ECM Regulation on its issue and use.

Additional information and clarification on marking:

The presence of the EC symbol shown on the left is to demonstrate the type of activity carried out.



The manufacturer must carry out the EC marking process before placing the product(s) on the market, and if the product(s) so requires, it must be submitted to a notified body. This document has been issued on the basis of the Voluntary Certificate Issuing Regulation number RCC_ECM rev. 0 and the Voluntary ECM Marking Regulation for product certification. RG01_ECM rev.3 both available at www.entecerma.it

Issuance date: 29 August 2022 Expiry date: 28 August 2027

Reviewer

Technical expert
Amanda Payne

Approver
Ente Certificazione Macchine
Legal Representative
Luca Bedonni





Verification No.: MK24110144P01-S05

Name and address of Guangdong Guangyu Cable Tray Co., Ltd

Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City,

Applicant:

Cuppedong Province

Guangdong Province

Name and address of Guangdong Guangyu Cable Tray Co., Ltd

Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City,

Guangdong Province

Product name: Steel Trough type cable tray

Rated: 200*100*1.5

GY-CSXJ-01 (200*100*1.5 L=2000mm),

Product model(s): GY-CSXJ-XX (XX stands for different sizes and specifications,

200*100*1.5mm L=2000mm) ≤1000mm Apply

Product trademark:

This verification confirms that the product meets the requirements of the following standard. The conformity was demonstrated based on following standard(s) listed by European Commission as harmonized with LVD Directive 2014/35/EU.

EN 61537:2007

The verification has been carried out in accordance with individual rules and conditions agreed with the applicant. Evaluation has been carried out in accordance with:

Test report(s) No.: MK24110144P01-S05

Test conducted by: TMC Testing Service Limited

Verification issue date: November 28, 2024

Notes:

This verification refers to the above mentioned product and its conformity in regards of above mentioned standard(s) was proven on test sample.

This verification does not imply meeting all essential requirements, assessment of the series-production or any other restricted Notified Bodies conformity assessment procedure appropriate for the product.

This verification holder shall use this verification in connection to Verification of Compliance and technical data relevant for the product the verification was issued.

TMC Testing Service Limited









MK24110144P01-S03 Verification No.:

Guangdong Guangyu Cable Tray Co., Ltd Name and address of

Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City, Applicant:

Guangdong Province

Guangdong Guangyu Cable Tray Co., Ltd Name and address of

Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City, Manufacturer:

Guangdong Province

Product name: Steel Ladder type cable tray

200*100*1.5mm Rated:

GY-TSXJ-01 (200*100*1.5mm)

Product model(s): GY-TSXJ-XXW (XX stands for different sizes and specifications,

200*100*1.5mm L=2000mm) ≤ 1000 mm Apply

Product trademark:

This verification confirms that the product meets the requirements of the following standard. The conformity was demonstrated based on following standard(s) listed by European Commission as harmonized with LVD Directive 2014/35/EU.

EN 61537:2007

The verification has been carried out in accordance with individual rules and conditions agreed with the applicant. Evaluation has been carried out in accordance with:

MK24110144P01-S03 Test report(s) No.:

Test conducted by: TMC Testing Service Limited

Verification issue date: November 28, 2024

Notes:

This verification refers to the above mentioned product and its conformity in regards of above mentioned standard(s) was proven on test sample.

This verification does not imply meeting all essential requirements, assessment of the series-production or any other restricted Notified Bodies conformity assessment procedure appropriate for the product.

This verification holder shall use this verification in connection to Verification of Compliance and technical data relevant for the product the verification was issued.

TMC Testing Service Limited









Verification No.: MK24110144P01-S01

Guangdong Guangyu Cable Tray Co., Ltd Name and address of

Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City, Applicant:

Guangdong Province

Guangdong Guangyu Cable Tray Co., Ltd Name and address of

Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City, Manufacturer:

Guangdong Province

Product name: **Aluminum Cable Ladder**

200 *45*31mm Rated:

GY-LHJZXJ-01 (W=200 *45*31mm)

Product model(s): GY-LHJZXJ-XXW (XX stands for different sizes and specifications,

 $W=200 *45*31mm \le 1000mm Apply$

Product trademark:

This verification confirms that the product meets the requirements of the following standard. The conformity was demonstrated based on following standard(s) listed by European Commission as harmonized with LVD Directive 2014/35/EU.

EN 61537:2007

The verification has been carried out in accordance with individual rules and conditions agreed with the applicant. Evaluation has been carried out in accordance with:

MK24110144P01-S01 Test report(s) No.:

Test conducted by: TMC Testing Service Limited

Verification issue date: November 28, 2024

Notes:

This verification refers to the above mentioned product and its conformity in regards of above mentioned standard(s) was proven on test sample.

This verification does not imply meeting all essential requirements, assessment of the series-production or any other restricted Notified Bodies conformity assessment procedure appropriate for the product.

This verification holder shall use this verification in connection to Verification of Compliance and technical data relevant for the product the verification was issued.

TMC Testing Service Limited









Verification No.: MK24110144P01-S07

Guangdong Guangyu Cable Tray Co., Ltd Name and address of

Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City, Applicant:

Guangdong Province

Guangdong Guangyu Cable Tray Co., Ltd Name and address of

Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City, Manufacturer:

Guangdong Province

Product name: **Fiber Cable Tray**

240*100*3.0 Rated:

GY-GXXJ-01 (240*100*3.0 L=2000mm)

Product model(s): GY-GXXJ-XX (XX stands for different sizes and specifications)

120*100*3.0mm L=2000mm 360*100*3.0mmL=2000mm Apply

Product trademark:

This verification confirms that the product meets the requirements of the following standard. The conformity was demonstrated based on following standard(s) listed by European Commission as harmonized with LVD Directive 2014/35/EU.

EN 61537:2007

The verification has been carried out in accordance with individual rules and conditions agreed with the applicant. Evaluation has been carried out in accordance with:

MK24110144P01-S07 Test report(s) No.:

Test conducted by: TMC Testing Service Limited

Verification issue date: November 28, 2024

Notes:

This verification refers to the above mentioned product and its conformity in regards of above mentioned standard(s) was proven on test sample.

This verification does not imply meeting all essential requirements, assessment of the series-production or any other restricted Notified Bodies conformity assessment procedure appropriate for the product.

This verification holder shall use this verification in connection to Verification of Compliance and technical data relevant for the product the verification was issued.

TMC Testing Service Limited









MK24110144P01-S09 Verification No.:

Guangdong Guangyu Cable Tray Co., Ltd Name and address of

Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City, Applicant:

Guangdong Province

Guangdong Guangyu Cable Tray Co., Ltd Name and address of

Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City, Manufacturer:

Guangdong Province

Product name: Grid cable tray

200*100*5.0 Rated:

GY-WGXJ-01 (200*100*5.0 L=2000mm).

Product model(s): GY-WGXJ-XX (XX stands for different sizes and specifications)

 $(200*100*5.0 L=2000mm) \leq 1000mm Apply$

Product trademark:

This verification confirms that the product meets the requirements of the following standard. The conformity was demonstrated based on following standard(s) listed by European Commission as harmonized with LVD Directive 2014/35/EU.

EN 61537:2007

The verification has been carried out in accordance with individual rules and conditions agreed with the applicant. Evaluation has been carried out in accordance with:

MK24110144P01-S09 Test report(s) No.:

Test conducted by: TMC Testing Service Limited

Verification issue date: November 28, 2024

Notes:

This verification refers to the above mentioned product and its conformity in regards of above mentioned standard(s) was proven on test sample.

This verification does not imply meeting all essential requirements, assessment of the series-production or any other restricted Notified Bodies conformity assessment procedure appropriate for the product.

This verification holder shall use this verification in connection to Verification of Compliance and technical data relevant for the product the verification was issued.

TMC Testing Service Limited









Verification No.: MK24110144P01-C03

Name and address of Guangdong Guangyu Cable Tray Co., Ltd

Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City,

Applicant:

Guangdong Province

Guangdong Guangyu Cable Tray Co., Ltd

Name and address of
Manufacturer:

Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City,

Guangdong Province

Product name: Steel Trough type cable tray

GY-CSXJ-01 (200*100*1.5 L=2000mm), GY-CSXJ-XX (XX stands for

Product model(s): different sizes and specifications, 200*100*1.5mm L=2000mm ≥ 1000mm

Apply

Product trademark:



This verification confirms that the product meets the requirements of the following standard.

The conformity was demonstrated based on following standard(s) listed by European Commission as harmonized with Directive RoHS 2.0 Directive (EU) 2015/863 and (EU)2017/2102 amending Annex II to Directive 2011/65/EU

IEC 62321-1:2013 IEC 62321-3-1:2013 IEC 62321-4:2013/AMD1:2017 IEC 62321-5:2013 IEC 62321-6:2015 IEC 62321-7-1:2015 IEC 62321-7-2:2017 IEC 62321-2:2014

The verification has been carried out in accordance with individual rules and conditions agreed with the applicant. Evaluation has been carried out in accordance with:

Test report(s) No.: MK24110144P01-C03

Test conducted by: TMC Testing Services (Shenzhen) Co., Ltd.

Verification issue date: December 04, 2024

Notes:

This verification refers to the above mentioned product and its conformity in regards of above mentioned standard(s) was proven on test sample.

This verification does not imply meeting all essential requirements, assessment of the series-production or any other restricted Notified Bodies conformity assessment procedure appropriate for the product.

This verification holder shall use this verification in connection to verification of conformity and technical data relevant for the product the verification was issued.

TMC Testing Services (Shenzhen) Co., Ltd.

t:86-755-86642861 cert@tmc-lab.com www.tmc-lab.com

1st Floor, Block A1, Zone A, Xinshidai Gongrong Industrial Park, No. 2, Shihuan Road, Shiyan Street, Baoan District, Shenzhen, China









Verification No.: MK24110144P01-C02

Name and address of Guangdong Guangyu Cable Tray Co., Ltd

Applicant: Guangdong Province

Guanguong i Tovince

Name and address of Guangdong Guangyu Cable Tray Co., Ltd

Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City,

Guangdong Province

Product name: Steel Ladder type cable tray

Product model(s):

GY-TSXJ-01 (200*100*1.5mm), GY-TSXJ-XXW (XX stands for different

sizes and specifications,200*100*1.5mm L=2000mm) ≤1000mm Apply

Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City,

Product trademark:



This verification confirms that the product meets the requirements of the following standard. The conformity was demonstrated based on following standard(s) listed by European Commission as harmonized with Directive RoHS 2.0 Directive (EU) 2015/863 and (EU)2017/2102 amending Annex II to Directive 2011/65/EU

IEC 62321-1:2013
IEC 62321-4:2013/AMD1:2017
IEC 62321-6:2015
IEC 62321-7-2:2017
IEC 62321-2:2014

IEC 62321-3-1:2013
IEC 62321-5:2013
IEC 62321-7-1:2015
IEC 62321-8:2017

The verification has been carried out in accordance with individual rules and conditions agreed with the applicant. Evaluation has been carried out in accordance with:

Test report(s) No.: MK24110144P01-C02

Test conducted by: TMC Testing Services (Shenzhen) Co., Ltd.

Verification issue date: December 04, 2024

Notes:

This verification refers to the above mentioned product and its conformity in regards of above mentioned standard(s) was proven on test sample.

This verification does not imply meeting all essential requirements, assessment of the series-production or any other restricted Notified Bodies conformity assessment procedure appropriate for the product.

This verification holder shall use this verification in connection to verification of conformity and technical data relevant for the product the verification was issued.

TMC Testing Services (Shenzhen) Co., Ltd.

t:86-755-86642861 cert@tmc-lab.com www.tmc-lab.com

1st Floor, Block A1, Zone A, Xinshidai Gongrong Industrial Park, No. 2, Shihuan Road, Shiyan Street, Baoan District, Shenzhen, China



CE

Lab Director Vivian Jiang



Verification No.: MK24110144P01-C01

Name and address of Guangdong Guangyu Cable Tray Co., Ltd

Applicant: Guangdong Province

Guangdong Guangyu Cable Tray Co., Ltd

Name and address of
Manufacturer:

Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City,

Guangdong Province

Product name: Aluminum Cable Ladder

GY-LHJZXJ-01 (W=200 *45*31mm), GY-LHJZXJ-XXW (XX stands for

different sizes and specifications,W=200 *45*31mm (≥ 1000mm Apply

Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City,

Product trademark:



This verification confirms that the product meets the requirements of the following standard. The conformity was demonstrated based on following standard(s) listed by European Commission as harmonized with Directive RoHS 2.0 Directive (EU) 2015/863 and (EU)2017/2102 amending Annex II to Directive 2011/65/EU

IEC 62321-1:2013
IEC 62321-4:2013/AMD1:2017
IEC 62321-6:2015
IEC 62321-7-2:2017
IEC 62321-2:2014

IEC 62321-3-1:2013
IEC 62321-5:2013
IEC 62321-7-1:2015
IEC 62321-8:2017

The verification has been carried out in accordance with individual rules and conditions agreed with the applicant. Evaluation has been carried out in accordance with:

Test report(s) No.: MK24110144P01-C01

Test conducted by: TMC Testing Services (Shenzhen) Co., Ltd.

Verification issue date: December 04, 2024

Notes:

This verification refers to the above mentioned product and its conformity in regards of above mentioned standard(s) was proven on test sample.

This verification does not imply meeting all essential requirements, assessment of the series-production or any other restricted Notified Bodies conformity assessment procedure appropriate for the product.

This verification holder shall use this verification in connection to verification of conformity and technical data relevant for the product the verification was issued.

TMC Testing Services (Shenzhen) Co., Ltd.

t:86-755-86642861 cert@tmc-lab.com www.tmc-lab.com

1st Floor, Block A1, Zone A, Xinshidai Gongrong Industrial Park, No. 2, Shihuan Road, Shiyan Street, Baoan District, Shenzhen, China



CE

Lab Director Vivian Jiang



Verification No.: MK24110144P01-C04

Name and address of Guangdong Guangyu Cable Tray Co., Ltd

Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City,

Applicant:

Guangdong Province

Guangdong Guangyu Cable Tray Co., Ltd

Name and address of

Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City,

Guangdong Province

Product name: Fiber Cable Tray

GY-GXXJ-01 (240*100*3.0 L=2000mm), GY-GXXJ-XX (XX stands for

Product model(s): different sizes and specifications) 120*100*3.0mm L=2000mm

360*100*3.0mmL=2000mm Apply

Product trademark:



This verification confirms that the product meets the requirements of the following standard.

The conformity was demonstrated based on following standard(s) listed by European Commission as harmonized with Directive RoHS 2.0 Directive (EU) 2015/863 and (EU)2017/2102 amending Annex II to Directive 2011/65/EU

IEC 62321-1:2013
IEC 62321-4:2013/AMD1:2017
IEC 62321-6:2015
IEC 62321-7-2:2017
IEC 62321-2:2014

IEC 62321-3-1:2013
IEC 62321-5:2013
IEC 62321-7-1:2015
IEC 62321-8:2017

The verification has been carried out in accordance with individual rules and conditions agreed with the applicant. Evaluation has been carried out in accordance with:

Test report(s) No.: MK24110144P01-C04

Test conducted by: TMC Testing Services (Shenzhen) Co., Ltd.

Verification issue date: December 04, 2024

Notes:

This verification refers to the above mentioned product and its conformity in regards of above mentioned standard(s) was proven on test sample.

This verification does not imply meeting all essential requirements, assessment of the series-production or any other restricted Notified Bodies conformity assessment procedure appropriate for the product.

This verification holder shall use this verification in connection to verification of conformity and technical data relevant for the product the verification was issued.

TMC Testing Services (Shenzhen) Co., Ltd.

t:86-755-86642861 cert@tmc-lab.com www.tmc-lab.com

1st Floor, Block A1, Zone A, Xinshidai Gongrong Industrial Park, No. 2, Shihuan Road, Shiyan Street, Baoan District, Shenzhen, China







Verification No.: MK24110144P01-C05

Name and address of Guangdong Guangyu Cable Tray Co., Ltd

Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City,

Applicant:

Guangdong Province

Guangdong Guangyu Cable Tray Co., Ltd

Name and address of Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City,

Guangdong Province

Product name: Grid cable tray

GY-WGXJ-01 (200*100*5.0 L=2000mm), GY-WGXJ-XX (XX stands for

Product model(s): different sizes and specifications) (200*100*5.0 L=2000mm)

≤1000mm Apply

Product trademark:



This verification confirms that the product meets the requirements of the following standard.

The conformity was demonstrated based on following standard(s) listed by European Commission as harmonized with Directive RoHS 2.0 Directive (EU) 2015/863 and (EU)2017/2102 amending Annex II to Directive 2011/65/EU

IEC 62321-1:2013 IEC 62321-3-1:2013 IEC 62321-4:2013/AMD1:2017 IEC 62321-5:2013 IEC 62321-6:2015 IEC 62321-7-1:2015 IEC 62321-7-2:2017 IEC 62321-2:2014

The verification has been carried out in accordance with individual rules and conditions agreed with the applicant. Evaluation has been carried out in accordance with:

Test report(s) No.: MK24110144P01-C05

Test conducted by: TMC Testing Services (Shenzhen) Co., Ltd.

Verification issue date: December 04, 2024

Notes:

This verification refers to the above mentioned product and its conformity in regards of above mentioned standard(s) was proven on test sample.

This verification does not imply meeting all essential requirements, assessment of the series-production or any other restricted Notified Bodies conformity assessment procedure appropriate for the product.

This verification holder shall use this verification in connection to verification of conformity and technical data relevant for the product the verification was issued.

TMC Testing Services (Shenzhen) Co., Ltd.

t:86-755-86642861 cert@tmc-lab.com www.tmc-lab.com

1st Floor, Block A1, Zone A, Xinshidai Gongrong Industrial Park, No. 2, Shihuan Road, Shiyan Street, Baoan District, Shenzhen, China





Lab Director Vivian Jiang

Report No. MK24110144P01-RL03

Test Report

Product Name: Steel Trough type cable tray

Product Model: GY-CSXJ-01 (200*100*1.5 L=2000mm)

XX stands for different sizes and Additional models:

specifications,200*100*1.5mm L=2000mm) ≤1000mm Apply

Sample material: Steel

Applicant: Guangdong Guangyu Cable Tray Co., Ltd

Manufacture: Guangdong Guangyu Cable Tray Co., Ltd

Test Model: Commissioned test

TMC Standard Testing Services (Shenzhen) Co., Ltd. Test Laboratory:

1/F of Building A1, 5/F. of Building B1, & 1/F. of Building A3,

Xinshidai Gongrong Industrial Park, No. 2, Shihuan Road, Address:

Shilong Community, Shiyan Subdistrict, Bao'an District,

Shenzhen, Guangdong, China




Report No. MK24110144P01-RL03

Product Name	Steel Trough type cable tray	Brand Name	1 TIME	LAUC LAUC
Applicant	Guangdong Guangyu Cable Tray Co., Ltd	Manufacture	Guangdong Guang	yu Cable Tray Co.,
Address	Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City, Guangdong Province, China	Address	Room 102, No. 11, Road, Daojiao Towr Guangdong Provinc	n, Dongguan City,
Sample Qty.	22 PCS	Sample Address	1 mc	
Sample Identify	Sample label	Sample	1	La. Lu
Sample Delivery	Sample from customer	Sample Receive:	2024-11-21	LANC LANC
Test Type	Commissioned test	C and	- anc	
Test Time	2024-11-22~ 2024-11-26	14	Lab environment	18.0℃~28.0℃ 45%RH~75%RH
Sample Description	Refer to Test Report	C LANC	- LAUC	LANC LANC
Model/Spec	GY-CSXJ-01 (200*100*1.5 L=2000r	mm)		
Test Standard	Refer to customer requirements and I	EC60068-2-11		.0 .0
Acceptance Criteria	Referring to customer requirements		Line Li	
Chinc Li	ye Inc Inc In	ic Line	- Lille	(mc Line
Test Result	Test data is detailed on the next page	S. THE		LANC LANC
WC TH	NC TANC TANC TAN	C THIC	- TENC	(检验单位盖章)
Notes:	a 20 20	C .C		, C , aC
Test by	Ethan Review by Zol	n Guangtong	Approval By	Zom. 2011.
WIL TH		u Guangtong 024-12-23	14VC	Tom Zou 2024-12-23



Report No. MK24110144P01-RL03

Group A/Group 1:UV test



Report No. MK24110144P01-RL02

Test Report

Product Name: Steel Ladder type cable tray

Product Model: GY-TSXJ-01 (200*100*1.5mm)

(XX stands for different sizes and Additional models:

specifications,200*100*1.5mm L=2000mm) ≤1000mm Apply

Sample material: Steel

Applicant: Guangdong Guangyu Cable Tray Co., Ltd

Manufacture: Guangdong Guangyu Cable Tray Co., Ltd

Test Model: Commissioned test

TMC Standard Testing Services (Shenzhen) Co., Ltd. **Test Laboratory:**

1/F of Building A1, 5/F. of Building B1, & 1/F. of Building A3,

Xinshidai Gongrong Industrial Park, No. 2, Shihuan Road, Address:

Shilong Community, Shiyan Subdistrict, Bao'an District,

Shenzhen, Guangdong, China




Report No. MK24110144P01-RL02

Product Name	Steel Ladder type cable tray	Brand Name	1 TIME	
Applicant	Guangdong Guangyu Cable Tray Co., Ltd	Manufacture	Guangdong Guang	yu Cable Tray Co.,
Address	Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City, Guangdong Province, China	Address	Room 102, No. 11, Road, Daojiao Town Guangdong Provinc	n, Dongguan City,
Sample Qty.	22 PCS	Sample Address	1 anc	anc and
Sample Identify	Sample label	Sample	1	la La
Sample Delivery	Sample from customer	Sample Receive:	2024-11-21	LANC LAN
Test Type	Commissioned test	C .mC	- inC	
Test Time	2024-11-22~ 2024-11-26	Y.A.	Lab environment	18.0℃~28.0℃ 45%RH~75%RH
Sample Description	Refer to Test Report	'C LANC	- TANC	LANC LAN
Model/Spec	GY-TSXJ-01 (200*100*1.5mm)			
Test Standard	Refer to customer requirements and I	EC60068-2-11		.c .c
Acceptance Criteria	Referring to customer requirements	Line	144	in Line
W. Li	Ve LENC LINE LEN	'C LEW	- Line	ing Line
Test Result	Test data is detailed on the next page:	S THE		LAUC LAU
MC TH	NC TANC TANC TAN	C THIC	- TENC	(检验单位盖章)
Notes:	a 2a 2a 2a	C .C		, C , a
Test by	Ethon Review by Zol	n Guangtong	Approval By	Zom. 2011.
7:91	30/1001			



Report No. MK24110144P01-RL02

Group A/Group 1:UV test



Report No. MK24110144P01-RL05

Test Report

Product Name: Grid cable tray

Product Model: GY-WGXJ-01 (200*100*5.0 L=2000mm)

XX stands for different sizes and Additional models:

specifications) $(200*100*5.0 L=2000mm) \leq 1000mm Apply$

Sample material: Steel

Applicant: Guangdong Guangyu Cable Tray Co., Ltd

Manufacture: Guangdong Guangyu Cable Tray Co., Ltd

Test Model: Commissioned test

TMC Standard Testing Services (Shenzhen) Co., Ltd. **Test Laboratory:**

1/F of Building A1, 5/F. of Building B1, & 1/F. of Building A3,

Xinshidai Gongrong Industrial Park, No. 2, Shihuan Road, Address:

Shilong Community, Shiyan Subdistrict, Bao'an District,

Shenzhen, Guangdong, China



Report No. MK24110144P01-RL05

Product Name	Grid cable tray	Brand Name	1 TIME	LAUC LAUC	
Applicant	Guangdong Guangyu Cable Tray Co., Ltd	Manufacture	Guangdong Guangyu Cable Tray Co., Ltd		
Address	Room 102, No. 11, North Ring West Road, Daojiao Town, Dongguan City, Guangdong Province, China	Address	Room 102, No. 11, Road, Daojiao Towi Guangdong Provinc	n, Dongguan City,	
Sample Qty.	2 PCS	Sample Address	1 anc	anc anc	
Sample Identify	Sample label	Sample	1	La. La.	
Sample Delivery	Sample from customer	Sample Receive:	2024-11-21	LAUC LAUC	
Test Type	Commissioned test	C .mC	- INC		
Test Time	2024-11-22~ 2024-11-26	Y.a.	Lab environment	18.0℃~28.0℃ 45%RH~75%RH	
Sample Description	Refer to Test Report	'C LANC	THIC	LANC LANC	
Model/Spec	GY-WGXJ-01 (200*100*5.0 L=2000)	mm)			
Test Standard	Refer to customer requirements and I	EC60068-2-11		.0 .0	
Acceptance Criteria	Referring to customer requirements		Laur L		
We Lu	Ve Line Line Lin	'C LEW	- Line	Line Line	
Test Result	Test data is detailed on the next pages	S. THE		LAUC LAUC	
MC TH	NC TANC TANC TAN	C THIN	TINC .	(检验单位盖章)	
Notes:	a 2a 2a	C .C	٠, ٥	aC aC	
Test by	Ethan Review by Zol	1 Guangtong	Approval By	70m. 2011.	



Report No. MK24110144P01-RL05

Group A/Group 1:UV test





TMC Testing Service Limited

Type Test Report

IEC 62262

Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts(IK code)

Tested by (Engineer)...... Gavin Zhang

Gavin Zhang

Report No.: MK24110144P01-S06

Approved by (Manager)..... Admire Xu

Admire Xu

Report Number.....: MK24110144P01-S06

Date of issue: December 4, 2024

Contents..... 8 pages

Testing laboratory

Name Service Limited

Address Unit 8B, 4 / F, Lippo Sun Plaza, 28 Canton Road, Tsim Sha Tsui,

Kowloon, Hong Kong

Testing location Same as above

Applicant's name.....: Guangdong Guangyu Cable Tray Co., Ltd

Address.....: Room 102, No. 11, North Ring West Road, Daojiao Town,

Dongguan City, Guangdong Province

Test specification

Standard...... IEC 62262:2002+A1:2021

Test procedure Compliance with IEC 62262:2002+A1:2021

Procedure deviation: N/A

Test item description.....: Steel Trough type cable tray

Manufacturer...... Guangdong Guangyu Cable Tray Co., Ltd

Address...... Room 102, No. 11, North Ring West Road, Daojiao Town,

Dongguan City, Guangdong Province

Trademark:



Model and/or type reference: GY-CSXJ-01 (200*100*1.5 L=2000mm),

GY-CSXJ-XX (XX stands for different sizes and specifications,

200*100*1.5mm L=2000mm) ≤1000mm Apply

Rating(s)...... 200*100*1.5

Report No.: MK24110144P01-S06

Attachment of Report — Photos



Fig.1 General view



Fig.2 General view

-END OF REPORT



TMC Testing Service Limited

Type Test Report

IEC 62262

Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts(IK code)

Tested by (Engineer)...... Gavin Zhang

Gavin Zhang

Report No.: MK24110144P01-S04

Approved by (Manager)..... Admire Xu

Admire Xu

Report Number.....: MK24110144P01-S04

Date of issue: December 4, 2024

Contents..... 8 pages

Testing laboratory

Name: TMC Testing Service Limited

AddressPlaza, 28 Canton Road, Tsim Sha Tsui,

Kowloon, Hong Kong

Testing location: Same as above

Applicant's name...... Guangdong Guangyu Cable Tray Co., Ltd

Address.....: Room 102, No. 11, North Ring West Road, Daojiao Town,

Dongguan City, Guangdong Province

Test specification

Standard.....: IEC 62262:2002+A1:2021

Test procedure Compliance with IEC 62262:2002+A1:2021

Procedure deviation: N/A

Test item description.....: Steel Ladder type cable tray

Manufacturer...... Guangdong Guangyu Cable Tray Co., Ltd

Address...... Room 102, No. 11, North Ring West Road, Daojiao Town,

Dongguan City, Guangdong Province

Trademark:



Model and/or type reference: GY-TSXJ-01 (200*100*1.5mm)

GY-TSXJ-XXW (XX stands for different sizes and specifications,

200*100*1.5mm L=2000mm) ≤ 1000 mm Apply

Rating(s)...... 200*100*1.5mm

Report No.: MK24110144P01-S04

Attachment of Report — Photos




Fig.1 General view



Fig.2 General view

-END OF REPORT-



TMC Testing Service Limited

Type Test Report

IEC 62262

Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts(IK code)

Tested by (Engineer)...... Gavin Zhang

Gavin Zhang

Report No.: MK24110144P01-S10

Approved by (Manager)..... Admire Xu

Admire Xu

Report Number.....: MK24110144P01-S10

Date of issue December 4, 2024

Contents..... 8 pages

Testing laboratory

Name TMC Testing Service Limited

Address Unit 8B, 4 / F, Lippo Sun Plaza, 28 Canton Road, Tsim Sha Tsui,

Kowloon, Hong Kong

Testing location Same as above

Applicant's name...... Guangdong Guangyu Cable Tray Co., Ltd

Address......: Room 102, No. 11, North Ring West Road, Daojiao Town,

Dongguan City, Guangdong Province

Test specification

Standard.....: IEC 62262:2002+A1:2021

Procedure deviation: N/A

Test item description...... Grid cable tray

Manufacturer...... Guangdong Guangyu Cable Tray Co., Ltd

Address...... Room 102, No. 11, North Ring West Road, Daojiao Town,

Dongguan City, Guangdong Province

Trademark:

G S

Model and/or type reference: GY-WGXJ-01 (200*100*5.0 L=2000mm),

GY-WGXJ-XX (XX stands for different sizes and specifications)

(200*100*5.0 L=2000mm) ≤1000mm Apply

Rating(s)...... 200*100*5.0

Report No.: MK24110144P01-S10

Attachment of Report — Photos



Fig.1 General view



Fig.2 General view

-END OF REPORT

Report No. MK24110144P01-RL08

Test Report

Product Name: Steel Trough type cable tray

Product Model: GY-CSXJ-01 (200*100*1.5 L=2000mm)

XX stands for different sizes and

Additional models: specifications,200*100*1.5mm L=2000mm) ≤1000mm Apply

Sample material: Steel

Applicant: Guangdong Guangyu Cable Tray Co., Ltd

Manufacture: Guangdong Guangyu Cable Tray Co., Ltd

Test Model: Commissioned test

TMC Standard Testing Services (Shenzhen) Co., Ltd. Test Laboratory:

1/F of Building A1, 5/F. of Building B1, & 1/F. of Building A3,

Xinshidai Gongrong Industrial Park, No. 2, Shihuan Road, Address:


Shilong Community, Shiyan Subdistrict, Bao'an District,

Shenzhen, Guangdong, China



Report No. MK24110144P01-RL08

Group A/No.1: Photos of Neutral salt spray test



Report No. MK24110144P01-RL07

Test Report

Product Name: Steel Ladder type cable tray

Product Model: GY-TSXJ-01 (200*100*1.5mm)

(XX stands for different sizes and

Additional models: specifications,200*100*1.5mm L=2000mm) ≤1000mm Apply

Sample material: Steel

Applicant: Guangdong Guangyu Cable Tray Co., Ltd

Manufacture: Guangdong Guangyu Cable Tray Co., Ltd

Test Model: Commissioned test

TMC Standard Testing Services (Shenzhen) Co., Ltd. **Test Laboratory:**

1/F of Building A1, 5/F. of Building B1, & 1/F. of Building A3,

Xinshidai Gongrong Industrial Park, No. 2, Shihuan Road, Address:


Shilong Community, Shiyan Subdistrict, Bao'an District,

Shenzhen, Guangdong, China



Report No. MK24110144P01-RL07

Group A/No.1: Photos of Neutral salt spray test



Shenzhen Headquarters

Company Name: Shenzhen Guangyu New Materials Co., Ltd.

Website: www.guangyuxc.com

Tel: +86-755-81790879 | +86-13602631980

Address: Unit 1702, Building C, No.37 Baoshi West Road, Shiyan Street, Bao'an District, Shenzhen, Guangdong, China

Factory 1 - Dongguan, Guangdong

Company Name: Guangdong Guangyu Cable Tray Co., Ltd.

Tel: +86-769-88831980

Address: Beihuan West Road, Dayusha Village, Daojiao Town, Dongguan, Guangdong, China

Factory 2 - Haikou, Hainan

Company Name: Hainan Guangyu Cable Tray Co., Ltd.

Tel: +86-898-66862012 | +86-13697537981

Address: Yongcangying Village, Yongxing Town, Xiuying District, Haikou, Hainan, China

Factory 3 - Kunming, Yunnan

Company Name: Yunnan Guangyu Industrial Co., Ltd.

Tel: +86-871-67450413 | +86-18213840258

Address: Building 30, ASEAN International Building Materials City, Qidian Industrial Park, Kunming, Yunnan, China

深圳總公司

公司名稱:深圳廣羽新材股份有限公司

公司網址: www.guangyuxc.com

聯系電話: 0755-81790879 13602631980

公司地址: 深圳市寶安區石岩街道寶石西路37號C單元1702

一廠(廣東東莞道 工廠)

公司名稱: 廣東廣羽電纜橋架有限公司

聯系電話: 0769-88831980

公司地址: 廣東省東莞市道 鎮大魚沙村北環西路

二廠 (海南海口工廠)

公司名稱:海南廣羽電纜橋架有限公司

聯系電話: 0898-66862012 13697537981

公司地址:海南省海口市秀英區永興鎮永蒼英村

三廠(雲南昆明工廠)

公司名稱: 雲南廣羽實業有限公司

聯系電話: 0871-67450413 18213840258

公司地址: 雲南省昆明市七甸工業園東盟國際建材城30棟



微信公衆號 Follow our WeChat Official Account